

# Altronic, Inc.

## Service Bulletin

Date: 4-19-04

Subject: GOV Flow Enable Instructions (Optional Feature)

The GOV10/50 is sold with or without the FLOW measurement turned on. If a unit is required to have the FLOW feature turned on in the field, it can be done using the Display Module after purchase of this optional feature. The cost for this option is the difference between the models listed in the price list. (\$1600.00 USER) To turn this feature on the following is required:

The Altronic Central Distributor must contact Altronic with a PO and the model and serial number of the GOV to have the Flow feature turned on (enabled). Also, a date code of the unit is required. The date code can be found by using the Display Module to enter the "Hardware Configuration" and scroll to the last screen. (F1 + F2 + SETUP to enter Configuration) This last screen of the Hardware Configuration will show GOVxxxx-xx >, where the xxxx-xx is the date code of the unit. Once this PO, date code, model number, and serial number are furnished, Altronic will provide a code number to be entered to the right of the date code. Once entered, the flow will be turned "ON", and this will show on this screen. See section 17.0 for details of the Hardware Configuration Variables Group.

