



Certificate of Compliance

Certificate: 1157042

Master Contract: 150143

Project: 1785608

Date Issued: 2006/07/26

Issued to: Altronic Inc.
712 Trumbull Ave
Girard, OH 44420
USA
Attention: Mr. G. Terry

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by: Ernest Klier, P. Eng.

Authorized by: Patricia Pasemko, Operations Manager

PRODUCTS

CLASS 4818 84 - SIGNAL APPLIANCES - Systems - For Hazardous Locations - Certified to US Standards

CLASS 4818 04 - SIGNAL APPLIANCES - Systems - For Hazardous Locations

Class I, Div. 2, Groups C and D:

- DD - 40NTa - x series Digital Annunciator System comprised of:

= Annunciator Module P/N DD-40NTa-O or , DD-40Nta- U were a is the feature set,

= Power Supply Module, P/N 691200-x, were x is output and input function set, rated 12 to 24V dc,

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



Certificate: 1157042

Master Contract: 150143

Project: 1785608

Date Issued: 2006/07/26

= Terminal Board Units, P/N 672169-x, where x is terminal layouts, used on -U units only.

Note: Equipment to be installed inside a Control Panel. Final installation to be approved by local authorities having jurisdiction.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 142-M1987 - Process Control Equipment

CSA Std C22.2 No. 213-M1987 - Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

UL Std No. 916 - Energy Management Equipment

UL Std No. 1604, Third Ed. - 1994 - Electrical Equipment for Use in Class I and II, Division 2; Class III Hazardous (Classified) Locations



Supplement to Certificate of Compliance

Certificate: 1157042

Master Contract: 150143

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
1785608	2006/07/26	DD-40NTa-x Annunciator.
1741224	2006/01/13	Revised Construction Model: DD-40NTS

History

1157042 July 11, 2001 DD-40NTS Digital Annunciator.