



**“NOTES”**  
**APPLICATION & SERVICE**

NUMBER: 15      DATE: February 12, 1996       APPLICATION     SERVICE

**SUBJECT: Keypads for EPC-200C and ETS 24/40**

Recent revisions to the sealed membrane keypads have improved their quality as well as addressed proper installation procedures. Since replacement keypads are subject to premature failure if bent during installation, Altronic has elected to factory install these keypads to a backing plate to minimize the possibility of damage during field replacement. Keypads installed at the Altronic factory are adhered directly to the door of the device, but replacement keypads will be sold as a kit with the keypad adhered to a backing plate with bezel, and new (longer) mounting screws. The process of field replacement is greatly simplified with the new part, which also minimizes installation errors and difficulties. To install this keypad it is not necessary to “stick” it onto the door. It is only necessary to screw the new plate and bezel on with the eight bezel screws. The old keypad, as well as any adhesive remaining on the door, must be removed prior to installing the replacement; at this point the new keypad is easily attached. The new part numbers and prices for these products are as follows:

<u>PRODUCT</u>	<u>DESCRIPTION</u>	<u>OLD PART NO.</u>	<u>NEW PART NO.</u>	<u>USER PRICE</u>
EPC-200C	Keypad assembly (EPC)	610 216	680 004-1	\$175.00
ETS 24/40	Keypad assembly (ETS)	610 217	680 004-2	\$175.00